

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 3 PAGES	
2. AMENDMENT/MODIFICATION NO. 04		3. EFFECTIVE DATE 12/19/2007		4. REQUISITION/PURCHASE REQ. NO. CB 070193		5A. TITLE: West Terrace Egress Doors and Stairs, U.S. Capitol	
						5B. PROJECT NO.	
6. ISSUED BY		CODE		9901		7. ADMINISTERED BY (If other than Item 6)	
AOC - Procurement Division 2nd & D Streets, SW Room H2-263 WASHINGTON, DC 20515						AOC - Procurement Division 2nd & D Streets, SW ATTN: Fred Witcher Room H2-263 WASHINGTON, DC 20515	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, country, state and ZIP Code)						(X) 9A. AMENDMENT OF SOLICITATION NO. RFP070123	
						X 9B. DATED (SEE ITEM 11) 11/14/2007	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended,

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 7 and 14, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)
SEE LINE ITEMS

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

This Amendment No. 04 is issued to provide responses to contractor questions. THE DUE DATE AND TIME FOR RECEIPT OF PROPOSALS REMAINS 28 DEC 07, 1:00 P.M.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
(Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)	
15C. DATE SIGNED		16C. DATE SIGNED	

NSN 7540-01-152-8070
Previous edition unusable

STANDARD FORM 30 (REV. 10-83)
Prescribed by GSA FAR (48 CFR) 53.243

RFP070123

Summary Info Continuation Page

B1

1. Question: Please provide total vertical foundation loading per lineal foot for the following locations: A) east wall room ST-22; B) north wall room ST-22; C) east wall room HT-18; and D) south wall room HT-18. This information is necessary to properly define the scope of the excavation support system.

Response: Estimated wall loads are as follows:

A) ST-22 east- 10,400#/ft dead load; 2700#/ft Live load

B) ST-22 north- 8000 #/ft dead load; 1450#/ft live load

C) HT-18 east- 10,400#/ft deadload; 2700#/ft live load

D) HT-18 south- 8000#/ft deadload; 1450#/ft live load

2. Question: With respect to the painting of the rails, it appears that specification section 09900, paragraph 2.4 lists both satin and semi-gloss paint however it is unclear as to which elements in the rail/screen assembly is to receive which finish. Additionally detail 1/A501 notes that the rails are to be painted with a fluoropolymer system where as the paint specification does not indicate fluoropolymer. Please review and advise.

Response: Provide semi-gloss finish as stated in the specs or approved equal:

Semi-Gloss Finish/Alkyd

Primer: 1 coat IronClad Latex Low Lustre Metal and Wood

Enamel (363), or touch-up shop primer

First Coat: 1 coat Alkyd Dulamel (207)

Second Coat: 1 coat Alkyd Dulamel (207)

a. Total DFT not less than: 4.0 mils

THE DUE DATE AND TIME FOR RECEIPT OF PROPOSALS REMAINS 28 DEC 07, 1:00 P.M.

THESE ARE THE FINAL QUESTIONS AND RESPONSES; NO MORE QUESTIONS WILL BE ACCEPTED.

THIS PAGE LEFT BLANK INTENTIONALLY